



Keegan Gulick <kgulick@migcom.com>

---

## Request for Comments on Master Planned Development - Aert's Addition (MPD 24-02)

---

Rodney Linz <rodneyl@banksfire.org>

Wed, Jun 12, 2024 at 4:23 PM

To: Keegan Gulick <kgulick@migcom.com>

Keegan,

After review of the information provided, I have no concerns. I do have one question since I was not able to find it or just simply overlooked it was the Fire Hydrant placement and I would like to make sure that all hydrants placed would have a 4" Storz fitting on the front main port.

Thank you,

Rodney

Rodney Linz

Fire Chief / DLO

Banks Fire District

[13430 NW Main Street](#)

[Banks, Or. 97106](#)

503-324-6262 Ext 101

E-mail [rodneyl@banksfire.org](mailto:rodneyl@banksfire.org)

[Quoted text hidden]